



EMSL Analytical, Inc.

1056 Stelton Road Piscataway, NJ 08854
Tel/Fax: (732) 981-0550 / (732) 981-0551
<http://www.EMSL.com> / piscatawaylab@emsl.com

EMSL Order: 052403272
Customer ID: ENVI65
Customer PO:
Project ID:

Attention: Mike Moore
Environmental Connection, Inc.
120 North Warren Street
Trenton, NJ 08608
Phone: (609) 392-4200
Fax:
Received Date: 07/17/2024 10:22 AM
Analysis Date: 07/17/2024
Collected Date: 07/17/2024
Project: 24202-02 / Wall Township BOE, Asbestos Abatement, Old Mill Elementary School

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
01MM071724 052403272-0001	Classroom 103	1200.00	0.0756	0	None Detected	0	0	0.0042	<13.00	<0.0042
02MM071724 052403272-0002	Classroom 114	1200.00	0.0756	0	None Detected	0	0	0.0042	<13.00	<0.0042
03MM071724 052403272-0003	Classroom 117	1200.00	0.0756	0	None Detected	0	0	0.0042	<13.00	<0.0042
04MM071724 052403272-0004	Classroom 119	1200.00	0.0756	0	None Detected	0	0	0.0042	<13.00	<0.0042
05MM071724 052403272-0005	Classroom 123	1200.00	0.0756	0	None Detected	0	0	0.0042	<13.00	<0.0042

Analyst(s)

Marc Williams (5)

C. Michael Slattery, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in structures/cm3 are not covered by the laboratory's NVLAP accreditation. Measurement of uncertainty available upon request.

Samples analyzed by EMSL Analytical, Inc. Piscataway, NJ NYS ELAP 11423, NVLAP Lab Code 101048-2, NJ NELAC 12037, Philadelphia 289, CT PH-0266

Initial report from: 07/17/2024 14:57 PM